



P.O. Box 625, Rt. 331S, Millsboro, DE 19966

August 24, 2011

Mr. Glenn Davis  
Program Manager  
Surface Water Discharges Section  
DNREC  
89 Kings Highway  
Dover DE 19901



RE: Compliance Sampling & Inspection  
NPDES Permit No. DE-0000736  
Follow-up Letter and Manager's Deficiency Warning  
Storm Water Outfall 004

Dear Mr. Davis

This letter serves as Pinnacle Foods Group LLC'S response to required corrective action for Storm Water Outfall 004.

The outfall has been power washed and vacuumed at both the in feed and discharge ends; photo's enclosed. In addition a U shaped slotted metal box with a removable bolt on lid has been installed at the parking lot end. This container covers the width of the drain and will contain oil absorbing socks and or mats in an effort to prevent any oil from entering the outfall; photo's enclosed. The container is fastened in place to prevent it from escaping during heavy rains. The oil absorbent materials will be monitored and changed as necessary. A weekly check sheet for monitoring/changing the absorbent material (copy enclosed) has been developed.

Should you have any questions please call me at 302-934-3833.

Sincerely,

A handwritten signature in blue ink that reads "Robert E. Lynch".

Robert E. Lynch  
Environmental/Wastewater Supervisor

Millsboro Delaware  
Storm Water Pollution Prevention Plan & Spill Prevention, Control and Countermeasures Plan  
**Weekly 004 absorbent check sheet**  
CALENDAR YEAR 2011

### Millsboro Delaware

**Storm Water Pollution Prevention Plan & Spill Prevention, Control and Countermeasures Plan**

**Weekly 004 absorbent check sheet**

**CALENDAR YEAR 2011**[illegible]

























